



Product Service

CERTIFICATE

No. B 001319 0002 Rev. 02

Holder of Certificate: **Advanced Surgetech Materials Ltd**

3 Rd Fl Bldg G Jinxiongda Technopark
Xingyuan Rd Datanglang Village, Dalingshan Town
511700 Dongguan, Guangdong
PEOPLE'S REPUBLIC OF CHINA

Production Facility(ies):

001319

Certification Mark:



Product:

Tubular fuses

Model(s):

**A10gPV9A, A10gPV10A, A10gPV12A, A10gPV15A,
A10gPV20A, A10gPV9A-TH, A10gPV10A-TH,
A10gPV12A-TH, A10gPV15A-TH, A10gPV20A-TH**

Parameters:

Rated voltage:	1000VDC
Rated current:	9A, 10A, 12A, 15A, 20A
Breaking range and utilization category:	gPV
Rated breaking capacity:	30kA
Size:	Type A; 10x38 mm
Ambient temperature:	-5°C to 40°C
Altitude:	Not exceed 2000m

Tested according to:

EN 60269-6:2011
EN 60269-1:2007/A2:2014
IEC 60269-6:2010
IEC 60269-1:2006/A2:2014

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.:

64100180112603

Valid until:

2023-10-15

Date,

2018-10-16

(Boris Ouyang)